RTD RESISTANCE PROBE THERMOMETER

- 304 SS closed end probe measures temperature
- Varies electrical resistance in proportion to temperature changes
- Communicates change in resistance to automated systems

OPTIONS

304 SST Thermowell

SPECIFICATION

The RTD shall have a 304 stainless steel closed end probe with a 1/2 inch NPT male with hex fitting process connection. The RTD shall change resistance in proportion to a change in temperature and be capable of connecting to a device (such as a signal conditioning card) which can convert that resistance change to a standard 4-20 mA signal.

MATERIALS OF CONSTRUCTION

NB 1 Cast Iron
304 SS Closed End
1/2" NPT Male w/Hex fitting
1/2" NPT Female
5½" or 11½"



RTD RESISTANCE PROBE THERMOMETER

APPLICATION DATA

- Building control systems
- Process control systems
- Systems utilizing the EPC Electro-Pneumatic Controller



ELECTRONIC PRESSURE TRANSMITTER

APPLICATION DATA

- Building control systems
- Process control systems
- Systems utilizing the EPC Electro-Pneumatic Controller

ELECTRONIC PRESSURE TRANSMITTER

- Solid state, calibrated transmitter measures pressure to ±0.5% accuracy
- Outputs 4-20 mA signal; 10-30 VDC unregulated; 100 ohms output impedance
- Integral metal diaphragm and polysilicon bridge are virtually unaffected by shock, vibration or mounting
- Available in ranges 0-30, 0-300 and 0-1000 psig, overpressure protected
- NEMA 4 compliant with cable or waterproof connector
- Operates in 40-200°F
- 1/8 NPT male or female process connection

SPECIFICATION

The Electronic Pressure Transmitter shall have a 1/8 NPT male or female 316 stainless steel process connection. The Electronic Pressure Transmitter shall measure pressure to $\pm 0.5\%$ accuracy and output a standard 4-20 mA signal with 100 ohms output impedance. The Electronic Pressure Transmitter shall be shock and vibration resistant, overpressure protected, operate within 40-200°F and be NEMA 4 compliant.

MATERIALS OF CONSTRUCTION

Case:	304 SS
Diaphragm:	17-4 PH SS
Process Connection:	316 SS

